Energy Consumption and Greenhouse Gas Emissions Reporting - for 2016

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan/2016 - Dec/2016
Sector	Municipal Service Board
Agency Sub-sector	Electricity
Organization Name	Union Water System Join Board of Management

Operation Name	Operation Type	Address	City	Postal Code	Total Floor Area	Unit	Avg hrs/wk	Annual Flow (ML)	Electricity Quantity	Electricity Unit	Natural Gas Quantity	Natural Gas Unit	Fuel Oil 1 & 2 Quantity	Fuel Oil 1 & 2 Unit	Fuel Oil 4 & 6 Quantity	Fuel Oil 4 & 6 Unit	Propane Quantity	Propane Unit	Coal Quantity	Coal Unit	Wood Quantity	Wood Unit	District Heating Quantity	District Heating Unit	Renewable?	If Yes, enter Emission Factor	District Cooling Quantity	District Cooling Unit	Renewable?	If Yes, enter Emission Factor	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	Energy Intensity (ekWh/Mega Litre)	Building / Operation Identifier	Comments
Stephenson Building	*Administrative offices and related facilities, including municipal council chambers*	*2160 Yonge Street*	*Toronto*	*M4A 2G5*	*135,594.00*	*Square feet*	*70*	*23516.60224*	*2,181,065.00000*	*kWh*	*125,300.00000*	*Cubic meter*		*Litre*		*Litre*		*Litre*		*Metric Tonne*		*Metric Tonne*	*26.73000*	*Giga Joule*	*No*	*0.00000*		*Giga Joule*	*No*	*0.00000*					*max. 255 characters*
Cottam Booster Station UWSS	Facilities related to the pumping of water	163 Talbot Street E	Cottam	N0R 1B0	0.00	Square feet	168	1937.15000	272,412.00000	kWh	6,483.28100	Cubic Meter																			0.00000	0.00000	0.00000		
Low Lift Pumping Station UWSS	Facilities related to the pumping of water	1E0 Conc Lot 9	Ruthven	N0P 2G0	0.00	Square feet	168	16687.90000	2,046,546.55000	kWh	9,523.31800	Cubic Meter																			0.00000	0.00000	0.00000		
Ruthven Water Treatment Plant	Facilities related to the treatment of water	1615 Union Avenue	Ruthven	N0P 2G0	0.00	Square feet	168	15414.76000	4,411,317.45750	kWh	80,942.71400	Cubic Meter																			0.00000	0.00000	0.00000		